

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1574:175 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561  
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

**DESIGN:** Model 472491 AC Communicator Module. This unit is designed to transmit reports to the central station when it is directly wired to the telephone line. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 12 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product designation and UL label.

**APPROVAL:** Listed as control unit accessory for use with listee's separately listed compatible fire alarm control units.

**NOTE:** Formerly 7300-0085:191

**XLF:** 7300-0078:195

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager